

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.8	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.9	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.4	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	Wk1	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK2	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK2	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK2	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.4	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.9	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.8	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK4	
Jul-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK4	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK1	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.8	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.1	WK2	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK2	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.3	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.9	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK3	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK4	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.8	WK4	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK4	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK4	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7	WK4	
Aug-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK4	
Sep-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1,2,3,4 no discharge	
Sep-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	0	WK1,2,3,4 no discharge	
Sep-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK1,2,3,4 no discharge	
Oct-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1,2,3,4 no discharge	
Oct-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	0	WK1,2,3,4 no discharge	
Oct-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK1,2,3,4 no discharge	
Nov-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1,2,3,4 & 5 no discharge	
Nov-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	0	WK1,2,3,4 & 5 no discharge	
Nov-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK1,2,3,4 & 5 no discharge	
Dec-12	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1,2,3,4 No discharge	
Dec-12	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	0	WK1,2,3,4 No discharge	
Dec-12	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK1,2,3,4 No discharge	
Jan-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK1,2,3,4 No discharge	
Jan-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	0	WK1,2,3,4 No discharge	
Jan-13	3751	Central Coast Sands	Point 1	B2 Water - TSS (<50mg/l)	0	WK1,2,3,4 No discharge	
Feb-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	0	WK 1,2,4 No discharge	
Feb-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	0	WK 1,2,4 No discharge	
Feb-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	0	WK 1,2,4 No discharge	
Feb-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3 Lab result	
Feb-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.9	WK 3 Lab result	
Feb-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 3 Lab result	
Feb-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	14	WK 3	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK 1 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	38	WK 1 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	27	WK 1	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 2 Lab result	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	17	WK 2 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 3 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 3 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	12	WK 3	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 4 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK 4 Lab result	
Mar-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 4	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 1 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	13	WK 1 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	12	WK 1	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 2 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 2 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 2	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 3 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	26	WK 3 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	17	WK 3	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 4 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	33	WK 4 Lab result	
Apr-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	30	WK 4	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.4	WK 1 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	14	WK 1 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 1	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 2 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 2 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 2	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK 3 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	13	WK 3 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 3	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 4 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	13	WK 4 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 4	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 5 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	5.9	WK 5 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	30	WK 5 Lab result	
May-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	33	WK 5	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.3	WK 1 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 1 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	22	WK 1	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.3	WK 2 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 2 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	16	WK 2	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK 3 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	11	WK 3 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 3	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK 4 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	12	WK 4 Lab result	
Jun-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	16	WK 4	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 1 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	22	WK 1 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	27	WK 1	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7	WK 2 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	22	WK 2 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	11	WK 2	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK 3 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	14	WK 3 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 3	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.4	WK 4 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<5	WK 4 Lab result	
Jul-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 4	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1 Lab result	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 1 Lab result	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<5	WK 1 Lab result	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 1	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Aug-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.1	WK 2	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<5	WK 2	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 2	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 3	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<5	WK 3	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	6	WK 3	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Sep-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Oct-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.01	WK 3	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	21	WK 3	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	22	WK 3	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Nov-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Dec-13	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Jan-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Feb-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.7	WK 1	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK 1	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 1	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.6	WK 2	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 2	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 2	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Mar-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.57	WK 1	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 1	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	12	WK 1	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.31	WK 2	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 2	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	17	WK 2	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.68	WK 3	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<5	WK 3	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 3	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.29	WK 4	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<5	WK 4	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 4	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 5	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.41	WK 5	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 5	
Apr-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 5	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.4	WK 1	
May-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 1	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	10	WK 1	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 2	
May-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	14	WK 2	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 2	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
May-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
May-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
May-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.53	WK 1	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<5	WK 1	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	5	WK 1	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.66	WK 2	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 2	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	10	WK 2	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.03	WK 4	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 4	
Jun-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	10	WK 4	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Jul-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	9.18	WK 4	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	17	WK 4	
Aug-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.35	WK 1	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	29	WK 1	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	27	WK 1	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.07	WK 2	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	14	WK 2	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 2	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.74	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.52	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	17	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.17	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	14	WK 3	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.92	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	10	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.98	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.45	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.46	WK 4	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.35	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.42	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 4	
Sep-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	<9	WK 4	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.28	WK 2	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 2	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	<9	WK 2	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Oct-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.45	WK 3	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 3	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	<9	WK 3	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Nov-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.08	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	14	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.07	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 1	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 1	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.54	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	9	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.09	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	24	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.93	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	30	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	17	WK 2	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Dec-14	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Jan-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Feb-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.68	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	5	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.75	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	5	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.39	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	5	WK 3	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.64	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	9	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	14	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.24	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	10	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.28	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 4	
Mar-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	12	WK 4	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2 Easter rain event, Heavy rain, Pit flooded	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.68	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	11	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	5.66	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	107	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.45	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	46	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.32	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	71	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	22	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.52	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	37	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	24	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.25	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	54	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.77	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	262	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2 Did not receive Lab results until 16/04/2015	EPA Phone Notification High TSS
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.22	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	160	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3 East Coast low storm event, heavy rain, Pit flooded	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.55	WK 3	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	72	WK 3	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	70	WK 3	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.48	WK 3	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	71	WK 3	
Apr-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	71	WK 3	EPA Phone Notification Loss of Power High TSS
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.06	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	40	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.39	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	13	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.48	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.45	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 1	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.36	WK 2	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	18	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	26	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.31	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	23	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.41	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	28	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	36	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	30	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	27	WK 2	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.1	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	38	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	55	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	9.1	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	43	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	60	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	12	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	16	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	18	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.3	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	35	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	40	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.8	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	37	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	35	WK 3	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	9	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	12	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	17	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	10	WK 4	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.4	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	9	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	9	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	11	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<2	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.3	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	26	WK 4	
May-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	24	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.2	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	30	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	55	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	5.8	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	17	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.1	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	16	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	13	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.3	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	23	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.2	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	16	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	23	WK 1	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	5.8	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	13	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	9.4	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 2	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	14	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	12	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	11	WK 2	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.4	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	14	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	11	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.7	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	16	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	18	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	19	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.1	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	40	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	24	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	22	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	21	WK 3	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.6	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	17	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.53	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	26	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	24	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.3	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	23	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	24	WK 4	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	No discharge for remainder of the month	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	No discharge for remainder of the month	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	No discharge for remainder of the month	
Jun-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	No discharge for remainder of the month	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 3	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 3	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	17	WK 3	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Jul-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Aug-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Sep-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	2	WK 3	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.5	WK 3	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	4	WK 3	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	5	WK 3	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 5	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.4	WK 5	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	<1	WK 5	
Oct-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	1.5	WK 5 October total water discharged 0.959ML	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.4	WK 2	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	9	WK 2	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 2	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7	WK 3	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	14	WK 3	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	18	WK 3	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Nov-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4 November total water discharged 0.959ML	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.4	WK 4	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8.8	WK 4	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	7	WK 4	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Dec-15	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5 December total water discharge 0.17ML	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.1	WK 1	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	22	WK 1	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	31	WK 1	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.5	WK 2	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	11	WK 2	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	16	WK 2	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK 3	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	3	WK 3	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	2	WK 3	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.5	WK 4	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	18	WK 4	
Jan-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	24	WK 4 January total water discharge 2.74 ML	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	9.2	WK 1 Notification to EPA Ref No C01723-2016 pH discrepancy with Lab, Onsite pH reading 8.42 Lab report explained reasons for discrepancy Holding Time, Buffering.	Yes
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	15	WK 1	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	14	WK 1	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.7	WK 2	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	33	WK 2	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	39	WK 2	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	8.1	WK 3	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK 3	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	8.3	WK 3	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Feb-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4 February total water discharge 1.37 ML	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Mar-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5 Total water discharge March NIL	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2 installed flow gate in discharge pipe	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3 Flow meter monitoring start date. 18/04/2016	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Apr-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4 Total water discharge for April NIL	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1 Installed water quality dosing pump system.	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
May-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2 Installed pH probe with dial up notification	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.1	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	2	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	2.3	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	1	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	2.9	WK 2	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.4	WK 3	
May-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	4	WK 3	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	6.5	WK 3	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
May-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.8	WK 4	
May-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	3	WK 4	
May-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	4.7	WK 4 Total water discharge for May 1.02 ML	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	Rain event
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	Rain event
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.8	WK 4	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	21	WK 4	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	35	WK 4	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 5	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 5	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	25	WK 5	
Jun-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	38	WK 5 Total water discharge June 0.204 ML	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 1	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	18	WK 1	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	29	WK 1	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.3	WK 2	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	10	WK 2	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	15	WK 2	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	Rain event
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.8	WK 3	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 3	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	13	WK 3	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.7	WK 4	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK 4	
Jul-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	12	WK 4 Total water discharge for July 2.60 ML	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.1	WK 2	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 2	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	14	WK 2	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7	WK 3	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 3	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	14	WK 3	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	Rain event
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK 4	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	8	WK 4	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	12	WK 4	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Aug-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5 Total water discharge for August 2.88 ML	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 1	Rain event
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.2	WK 1	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	7	WK 1	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	11	WK 1	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 2	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.5	WK 2	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	5	WK 2	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	6.4	WK 2	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 4	Rain event
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	7.4	WK 4	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	6	WK 4	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	12	WK 4	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Sep-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5 Total water discharge for September 2.75 ML	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	<5	WK 3	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	6.9	WK 3	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	3	WK 3	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	6	WK 3	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Oct-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4 Total water discharge for October 0.137 ML	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	
Nov-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5 Total water discharged for November NIL ML	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Dec-16	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4 Total water discharged for December NIL ML	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 1	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 1	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 1	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 1	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 2	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 2	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 2	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 2	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 3	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 3	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 3	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 3	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 4	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 4	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 4	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 4	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Oil & Grease (<10mg/l)	No discharge	WK 5	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Ph (6.5-8.5)	No discharge	WK 5	
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - TSS (<50mg/l)	No discharge	WK 5	

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact
Jan-17	3751	Central Coast Sands	Point 2	B2 Water - Turbidity	No discharge	WK 5 Total water discharged for January 2017 NIL ML	