

HANSON EPA LICENSE CONDITIONS - Public Monitoring Register



Date	License No.	Site Name	Monitoring Location	Test Type	Result	Comments	EPA contact	
21.02.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	7.5	2 monthly test and test to discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	5		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	0.4			
22.03.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	8.0	Test to discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	7		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	2.6			
26.03.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	7.8	Test to discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	13		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	2.1			
24.04.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	7.7	2 monthly test and test to discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	<3		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	0.5			
4.06.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	7.5	2 monthly test and test to discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	<3		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	0.32			
04.07.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	7.7	Discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	3		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	0.22			
28.08.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	8.1	2 monthly test and test to discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	<3		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	0.88			
26.10.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	8.3	2 monthly test and test to discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	5		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	0.45			
10.12.2018	5289	Sancrox Quarry	Discharge point	B2 Water - Ph (6.5-8.5)	7.7	2 monthly test, no discharge		
	5289	Sancrox Quarry	Discharge point	B2 Water - Oil & Grease (<10mg/l)	Not visible			
	5289	Sancrox Quarry	Discharge point	B2 Water - TSS (<50mg/l)	3		TSS at Sancrox has <30mg/l limit not 50mg/l	
	5289	Sancrox Quarry	Discharge point	B2 Water - TN	0.38			